




Individual compressor disabled

Applicable to any outdoor unit within system
Operation continues normally



Compressor or IPDU board trouble

Disable only one by Bit 1, 2 or 3 **ON**

	Bit 1	Bit 2	Bit 3	Bit 4
Initial setup at shipment from factory	Off	Off	Off	Off
No.1 compressor if defective	ON	Off	Off	Off
No.2 compressor if defective	Off	ON	Off	Off
No.3 compressor if defective	Off	Off	ON	Off

System back up must be used for no more than 7 days